

## UNION COUNTY HEALTH DEPARTMENT

6 W SOUTH ST STE 2  
LIBERTY, IN 47353-1329  
[www.uchd.com](http://www.uchd.com)

(765) 458-5393

Fax (765) 458-5582

December 18, 2008

Brookville Lake Resort  
2288 West Old 101 Road  
Liberty, IN 47353

### SUBJECT: POOL & SPA COMPLIANCE FOR 2009

Dear Owner/Operator:

#### Virginia Graeme Baker Pool & Spa Safety Act

By December 19, 2008, ALL public pool & spa owners/operators must:

- Install drain covers that meet the ANSI/ASME A112.19.8-2007 standard on EVERY drain/grate. A list of cover manufacturers can be found at <http://www.epsc.gov/businfo/draineman.html>
- Install an automatic shut-off system, gravity drainage system, Safety Vacuum Release System (SVRS), suction-limiting vent system or disable the drain, if the pool operates off of a SINGLE main drain. Pools and spas with unblockable drains are exempt from this requirement. A list of SVRS manufacturers can be found at <http://www.epsc.gov/businfo/draineman.html>
- Ensure that dual or multiple main drains are at least 3 feet apart.

Pools And Spas Not Open On December 19, 2008 Are Not Required To Be In Compliance Until The Day The Pool Or Spa Is Re-opened!


#### All Union County Public Pools and Spas Shall Be in Compliance PRIOR TO OPENING IN 2009

- Installation of drain covers shall be certified by the manufacturer.
- The correct design and construction of an automatic shut-off system, gravity drainage system, Safety Vacuum Release System (SVRS), suction-limiting vent system shall be certified by an approved manufacturer or design professional and operation inspected and certified by a licensed inspector specified by the approved manufacturer or design professional.
- All certifications and inspections shall be submitted to the Union County Health Department PRIOR TO OPENING IN 2009.

**ALL POOLS AND SPAS NOT IN COMPLIANCE SHALL REMAIN CLOSED.**

Direct any questions to our office.

Respectfully,



Ronald E. Parker, Sanitarian  
Union County Health Department